

**COMMISSIONERATE OF HYDERABAD DISASTER RESPONSE AND
ASSET PROTECTION AGENCY (HYDRAA)**

From
The Commissioner,
Hyderabad Disaster Response
and Asset Protection Agency,
(HYDRAA).

To
The Management
Montfort School,
Sy. Nos.114/1, 116, 117,
Plot No. 7,
Jahanuma, Hyderabad.

Rc. No. 515/COM./HYDRAA/2025, Dated: 29-07-2025.

Sub: - Commissionerate - HYDRAA - Existing non high-rise building of Montfort School consisting of Cellar + Ground + 3 Upper Floors situated at Sy.Nos.114/1, 116, 117, Plot No. 7, Jahanuma, Hyderabad - **Renewal of Fire No Objection Certificate - Issued- Regarding.**

- Ref: - 1. Proceeding Rc. No. 5041/B2/97, Dated 12-03-2010 of the Director General of the State Disaster Response and Fire Services Department, Andhra Pradesh, Hyderabad.
2. Proceedings No.DM/0011/2018/D(VK) EVDM/2018, dt. 29.06.2018 of the Commissioner, GHMC.
3. Fire NOC vide Rc.No.DM/0398/2019, dated: 06.03.2019 of the Director, EV&DM, GHMC.
4. Renewal of Fire NOC vide Rc.No. e-752443/2024 Dated: 06.08.2024 issued by the Director, EV&DM, GHMC.
5. G.O.MS.No. 99, MA&UD, (GHMC.I) Department, Dt: 19-07-2024.
6. Application of the Management, dt: 17-07-2025, with original challan, received through Inward No.515, dt: 17-07-2025 of the Commissioner, HYDRAA.
7. Inspection report date: 29-07-2025.

*** **

Vide reference above 3rd cited, the Fire No Objection Certificate was issued and the same was also renewed for the existing non high-rise building of Montfort School consisting of Cellar + Ground + 3 Upper Floors situated at Sy. Nos.114/1, 116, 117, Plot No. 7, Jahanuma, Hyderabad vide reference above 4th cited. Vide reference above 6th cited, the management has applied now, for further renewal of Fire No Objection Certificate.

2. Vide reference above 7th cited, the team has inspected the above building and submitted the report as under:


3. Particulars of the Building:

a)	Name &Address of the building	Montfort School, Sy. Nos.114/1, 116, 117, Plot No. 7, Jahanuma, Hyderabad
b)	Plot Area/Height	7879.69 Sq. Meters/ 13.00 Meters
c)	No of floors	Cellar + Ground + 3 Upper Floors
d)	Name of the Owner / Occupier with mobile no.	The Management, @ Mobile No.7013356292
e)	Map Location	17.343696° 78.462658°

3. Emergency power generator etc., and associated equipment should be tested periodically, verified as per NBC, and IS-1646.
4. Every room with a capacity of 45 students shall be maintained minimum two doorways.
5. Evacuation plan showing exit routes and recommended action plan be displayed at conspicuous locations and shall be exhibited all times, all escape /exit routes shall not be blocked or encroached.
6. Fresh NOC would be required for any change in occupancy or additions/alterations in the building structure as per NBC of India and building bye/laws.
7. The Management has to maintain Fire Safety Measures at all times in good working Condition as seen during the inspection.
8. Any Loss of life or property due to Non - functioning of Fire Safety Measures and other installations shall be the responsibility of the management/owner.
9. All the Occupants must know the correct method of operation of the First Aid Fire Fighting System installed.
10. All Security personnel shall be trained to operate the Fire Safety Equipment during the Emergency.
11. Additional/Alteration, if any, in the building may be verified by building authority.
12. This Renewal of Fire No Objection Certificate is valid for one (01) year and shall be renewed every year. It is the responsibility of the owner/occupier to apply for renewal before two months of its expiry.

In view of the above, the **Renewal of Fire No Objection Certificate** is issued to the existing non high-rise building of Montfort School consisting of Cellar + Ground + 3 Upper Floors situated at Sy. Nos.114/1, 116, 117, Plot No. 7, Jahanuma, Hyderabad.


Commissioner,
Hyderabad Disaster Response &
Asset Protection Agency.


PRINCIPAL
PRINCIPAL
MONTFORT SCHOOL
JAHANUMA, HYD-53. T.S.