

**Office of the Asst.
Medical Officer of Health
Circle No. 10, CRZ, GHMC**

Rc. No. /H5/HS/Cir.10


Date: 08-05-2026

SANITARY CERTIFICATE

Certify that the MONTFORT SCHOOL Situated at 19-2-75/76, Jahanuma, Hyderabad – 053, T.S., the accommodation provided for each of the several classes is sufficient for maximum number of pupils taught therein, and is properly ventilated and lighted that is neat and clean that the latrine arrangements are adequate and satisfactory, that the supply of drinking water is wholesome and that in all other necessary respect the sanitation is Satisfactory. There is NO OBJECTION to run the school.



Asst. Medical Officer of Health
Circle No. 10, CRZM, GHMC



PRINCIPAL
PRINCIPAL
MONTFORT SCHOOL
JAHANUMA, HYD-53. T.S.


MEDICAL OFFICER
UPHC JAHANUMA
H.No.19-3-13, Opp. Urdu School for Boys,
Shamsheer Gunj 'X' Road,
Shama Talkies, Falaknuma, Hyderabad.

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No.

Dated: 08-05-2026

It is certified that an inspection team headed by Dr. AYESHA FATIMA (M.O) (Name of Officers with designation) from UPHC- JAHANUMA PHED inspected the MONTFORT SCHOOL, Jahanuma, Falaknuma (P.O), Hyderabad - 500053 (Name & Address of the school) on 08-05-2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. CEL/W/3229/05-26-001 dated 06-05-2026 of (PHED Lab) certified that the MONTFORT SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. This certificate is valid till 08-06-2027

Signature with Seal : 

Name

Dr. AYESHA FATIMA

Designation

MEDICAL OFFICER

Name & Address of the Office / Department :

MEDICAL OFFICER
UPHC JAHANUMA
H.No.19-3-13, Opp. Urdu School for Boys,
Shamsheer Gunj 'X' Road,
Shama Talkies, Falaknuma, Hyderabad.


To

MONTFORT SCHOOL,

Jahanuma, Falaknuma (P.O),

Hyderabad - 500053

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


PRINCIPAL
PRINCIPAL
MONTFORT SCHOOL
JAHANUMA, HYD-53. T.S.

TEST REPORT

Name and Address of the Client: M/S. Montfort School 8FV7+H5G, Montfort School (CBSE), St. Marks Boys Town High School, Ali Bagh, Model Town Colony, Nawab Saheb Kunta, Hyderabad, Telangana 500053,		Sample Registration : 3229/05/26-001 Test Report No : CEL/W/3229/05/26-001 Report Issued Date: : 06.05.2026 Your Reference : Nil Date of Receipt : 02.05.2026
Group : Water Discipline : Chemical & Biological Sample Description : Drinking Water-Girls Building Sample Quantity : 1 Liter Sample Packing : Clean & Sterile Container	Date of Registration	02.05.2026
	Date of Commencement of Testing	02.05.2026
	Date of Completion of Testing	06.05.2026
	Sample Condition of Receipt	Found Ok
	Sample Tested as Received Basis	
Sampling Details		
Date of Sampling: 02.05.2026		Environment Condition: Temperature :28.6° C, Humidity: 56%
Sampling Method: APHA 24 th Edition-1060-B		Sample Location: From Site
Sample Collected By: CEL Representative		



TEST RESULT

S. No	TEST PARAMETERS	TEST METHOD	UNITS	RESULTS	Acceptable Limits (As Per IS: 10500:2012)
1.	pH@25.0°C	IS 3025 (Part-11) 1983 :RA-2017	--	7.03	6.5 - 8.5
2.	Electrical Conductivity	IS 3025 (Part-14) 2013	µs/cm	226	Not Specified
3.	Total Dissolved Solids	IS 3025 (Part-16) 1984 :RA-2017	mg/l	104	Max. 500
4.	Turbidity	IS 3025 (Part-10) 1984 :RA-2017	NTU	< 1.0	Max. 1.0
5.	Odor	IS 3025 (Part-5) 2018	--	Agreeable	Agreeable
6.	Color	IS 3025 (Part-4) 1983 :RA-2017	CU	< 1.0	Max. 5.0
7.	Total Alkalinity as CaCO ₃	IS 3025 (Part-23) 1986 :RA-2003	mg/l	56	Max. 200
8.	Total Hardness as CaCO ₃	IS 3025 (Part-21) 2009 :RA-2019	mg/l	32	Max. 200
9.	Calcium as Ca	IS 3025 (Part-40) 1991 :RA-2003	mg/l	8.0	Max. 75
10.	Magnesium as Mg	IS 3025 (Part-46) 1994 :RA-2003	mg/l	2.9	Max. 30
11.	Chlorides as Cl	IS 3025 (Part-32) 1988 :RA-2019	mg/l	28	Max. 250
12.	Sodium as Na	APHA 24 th Edition-3500 Na B	mg/l	16	Not Specified
13.	Potassium as K	APHA 24 th Edition-3500 K B	mg/l	2.0	Not Specified
14.	Sulphates as SO ₄	IS 3025 (Part-24) 1986 :RA-2003	mg/l	7.6	Max. 200
15.	Nitrates as NO ₃	APHA 24 th Edition 4500 NO ₃ -C	mg/l	< 1.0	Max. 45
16.	Iron as Fe	IS 3025 (Part-53) 2003	mg/l	< 0.1	Max. 1.0
17.	Fluoride as F	IS 3025 (Part-60) 2008	mg/l	0.32	Max. 1.0
18.	Silica as SiO ₂	IS 3025 (Part 35) 1998 :RA-2003	mg/l	< 0.1	Not Specified

MICROBIOLOGICAL ANALYSIS

19.	Total Bacterial Count	IS 1622: 1981	Cfu/ml	16	Not Specified
20.	Coliforms	IS 15185: 2016	Per 100ml	Absent	Absent/100ml
21.	Escherichia coli	IS 15185: 2016	Per 100ml	Absent	Absent/100ml

APHA - American Public Health Association IS - Indian Standard ISO - International Organization for Standardization, CFU - Colony Forming Units.

 Verified By

 T. Jyothirmai
 (Sr. Chemist)


*****END OF THE REPORT*****